# Stratos 24 and 30 Chandelier

# TECH LIGHTING

CHANDELIER

#### **GENERAL PRODUCT INFORMATION:**



These fixtures are intended to be installed utilizing NEC compliant junction boxes.

This product is suitable for damp locations.

This product can be dimmed with a TRIAC, low-voltage electronic or 0-10V dimmer.

#### **CAUTION - RISK OF FIRE**

This product must be installed in accordance with the applicable installation code by a person familiar with the construction and operation of the product and the hazards involved.

Use minimum 90°C supply conductors.

#### SAVE THESE INSTRUCTIONS!



#### **Prepare the Canopy**



Remove the crossbar from the canopy by completely unscrewing the decorative bolt.



2 Mount the crossbar assembly to the electrical box with the two provided #8-32 screws.





## Shorten the Cords (Optional)



**NOTE:** If shortening is necessary, ensure that the cable identifiers are not removed during installation. If no shortening is necessary, skip to section 3A.

- Leave 8" behind for wire connections, cut off the excess cord. NOTE: This fixture contains one dummy coaxial cable.
- From the end of the cord, strip the jacket and braided shield 4" using a sharp knife. <u>Make sure not to nick the</u> <u>center wire</u>.
- Strip the insulation from the end of the center wire to expose the conductor.

#### Wire the Fixture



- 1 Connect the fixture ground wire to a suitable ground in accordance with local electrical codes.
- Connect the red driver wire labeled "+" (positive) to the fixture wire labeled "+"(positive) with a wire nut NOTE: Ensure that the inner conductor is being connected, not the braided coaxial shield (see diagram in 2A).
- Connect the black driver wire labeled "-" (negative) to the fixture wire labeled "-" (negative)with a wire nut NOTE: Ensure that the inner conductor is being connected, not the braided coaxial shield (see diagram in 2A).
- Connect the black 120V input to the hot power line wire with a wire nut.
- **5** Connect the white 120V input to the neutral power line wire with a wire nut.
- 6 Connect the purple and grey wires for a 0-10V dimming application.

**NOTE:** The purple and gray wires are only used for 0-10v dimming. For all other applications, use wire nuts to cap off and do not use the purple and grey wires.

#### **Complete Installation**



- Place all wires and wire nut connections properly inside the canopy.
- 2 Align the canopy center hole with the crossbar center hole.
- 3 Slide the canopy up against the ceiling and secure it in place by tightening the decorative bolt.

## Additional Leveling (optional)

**NOTE:** If necessary, minor leveling adjustments to the fixture may be needed. It is recommended that one person hold the fixture straight with the use of a level while the other adjusts the coaxial cable.

**CAUTION:** Only pull out extra cable for leveling if enough cord was left behind the canopy. Minimal amounts of cord should be pulled out for fine leveling.



## **CAUTION:** Make sure to support the fixture if fine leveling is necessary.

- Loosen (do not remove) the set screws on the canopy strain relief on the side which needs adjusting.
- Evenly and gently pull out the coaxial cable, in very small increments, through the strain relief to adjust whichever side to level the fixture.
- 3 Ensure that the fixture is level and re-tighten the set screw on the strain relief.

## Install Glass Panels



www.techlighting.com